



Leon County

Board of County Commissioners

301 South Monroe Street, Tallahassee, Florida 32301
(850) 606-5302 www.leoncountyfl.gov

Purchasing Division
1800-3 Blair Stone Road
(corner of Miccosukee and Blair Stone Roads)
Tallahassee, Florida 32308
(850) 606-1600

Commissioners

BILL PROCTOR
District 1

JANE G. SAULS
District 2

JOHN DAILEY
District 3

BRYAN DESLOGE
District 4

KRISTIN DOZIER
District 5

MARY ANN LINDLEY
At-Large

NICK MADDOX
At-Large

VINCENT S. LONG
County Administrator

HERBERT W.A. THIELE
County Attorney

December 30, 2013

RE: Bid Title: Lanier St and Horace Rd Drainage Maintenance Project
Bid No: BC-01-06-14-16
Opening Date: Monday, January 6, 2014 at 2:00 PM

ADDENDUM #2

Dear Vendor:

This letter serves as Addendum #2 for the above referenced project.

The following shall be added to the bid specifications:

QUESTION 1: We could not find the station markers with the plans. We had to guess the locations from the tree planting plan.

RESPONSE: Stationing has not been set in the field. The contractor will need to have the stationing set according to that shown in the Plans, as provided by Leon County Public Works.

QUESTION 2: Please identify the stations to correspond with the plans.

RESPONSE: See the Response to Question 1 above.

QUESTION 3: Please provide an acceptable list of grouting contractors.

RESPONSE: The following 2 Grouting Subcontractors should have the appropriate experience and equipment; although, there may be others:

Foundation Professionals of Florida, Lake City 386-755-3002

Alpha Foundation Specialist, Inc. Tallahassee 850-629-2000

QUESTION 4: I could not find an elevation for the bottom of the 30" pipe at the bottom of the concrete box.

RESPONSE: The elevation for the bottom of the 30" pipe is shown on section A-A' on page 5 of 12.

QUESTION 5: I did not find a plan view matching the elevations for B-B' and D-D'.

RESPONSE: The elevations are not shown on the plan view. However, the elevations are shown on the Front Elevations and Sections on page 5 of 12.

Addendum #2
Lanier St and Horace Rd Drainage Maintenance Project
December 30, 2013

QUESTION 6: How are we to obtain a compaction test while the water level in the drainage ditch is the same as the lakes? Geologist will not take the test in wet conditions. Even if we block the water from the work area. The ground water will remain. Please let us know how to accomplish the test.

RESPONSE: We concur – the compaction requirements have been revised on Sheet 2 of 12 and on Sheet 5 of 12 to eliminate the need for comp 0 action testing.

QUESTION 7: We could not find a staging area for loading trucks or trailers.

RESPONSE: No staging area is provided for the Contractor by the County. This is a responsibility of the Contractor.

GENERAL COMMENTS:


The waterline shown on the Horace Plan Set will be relocated by the utility provider (Lake Talquin Water).

The trees to be planted on the Lanier site will be planted by others after the contractor finishes their work.

Acknowledgment of this addendum is required as part of your bid submittal. Failure to acknowledge this addendum may result in rejection of your bid.

Should you have any questions, feel free to call me at (850) 606-1600.

Sincerely,



Don Tobin
Purchasing and Contracting Administrator

DT.