



Leon County

Board of County Commissioners

301 South Monroe Street, Tallahassee, Florida 32301
(850) 606-5302 www.leoncountyfl.gov

Purchasing Division
1800-3 Blair Stone Road
(corner of Miccosukee and Blair Stone Roads)
Tallahassee, Florida 32308
(850) 606-1600

Commissioners

BILL PROCTOR
District 1

JANE G. SAULS
District 2

JOHN DAILEY
District 3

BRYAN DESLOGE
District 4

KRISTIN DOZIER
District 5

MARY ANN LINDLEY
At-Large

NICK MADDOX
At-Large

VINCENT S. LONG
County Administrator

HERBERT W.A. THIELE
County Attorney

November 4, 2013

RE: Bid Title: Bank of America Building Waterproofing
Bid No: BC-11-14-13-09
Opening Date: **CHANGED TO: November 21, 2013 at 2:00 PM**

ADDENDUM #1

Dear Vendor:

This letter serves as Addendum #1 for the above referenced project.

The Bid Opening has been changed to November 21, 2013 at 2:00 PM

This addendum forms a part of the contract documents and modifies the original specifications and drawings, dated March 14, 2013, as noted below. Acknowledge receipt of the Addendum in the space provided on the proposal form. Failure to do so may subject Bidder to disqualification.

The following shall be added to the bid specifications:

ITEM NO. 1 - PROJECT MANUAL, SECTION 01010, SUMMARY OF WORK, DRAWINGS SHEETS G100, SCOPE OF WORK and A000 RENOVATION NOTES.

Delete: All work associated with Alternates #1 and #4

Change: Construction period from 150 days to 90 days.

ITEM NO. 2 - PROJECT MANUAL, SECTION 01010, SUMMARY OF WORK, DRAWINGS SHEETS G100, SCOPE OF WORK and A000 RENOVATION NOTES.

Add: Additive Alternate #5 - Provide cost for additional inspection/ stage time and sealant repairs for independent third party inspector (provided by owner) and added warranty cost to provide a 20 year labor and material sealant warranty.

ITEM NO. 3 - DRAWINGS SHEET A000, RENOVATION ROOF PLAN, SHEET A500, DETAILS

Clarification: Base bid to include 12 linear feet of saw cut out and 3 cubic feet of spalled concrete repair work on the south elevation of the precast concrete west side entrance. Contractor to include a cost per cubic foot (\$_/cf) for additional concrete repair.


Clarification: Contractors are to paint and seal as much as can be accessed with the existing Bank of America signage on the east elevation of the building remaining in place.

Addendum #1: Bank of America Building Waterproofing
November 4, 2013
Page 2

Acknowledgment of this addendum is required as part of your bid submittal. Failure to acknowledge this addendum may result in rejection of your bid.

Should you have any questions, feel free to call me at (850) 606-1600.

Sincerely,



Don Tobin, CPPB
Purchasing and Contracting Administrator

DT