



Leon County

Board of County Commissioners

301 South Monroe Street, Tallahassee, Florida 32301
(850) 606-5302 www.leoncountyfl.gov

Purchasing Division
1800-3 Blair Stone Road
(corner of Miccosukee and Blair Stone Roads)
Tallahassee, Florida 32308
(850) 606-1600

Commissioners

BILL PROCTOR
District 1

JANE G. SAULS
District 2

JOHN DAILEY
District 3

BRYAN DESLOGE
District 4

KRISTIN DOZIER
District 5

NICK MADDOX
At-Large

AKIN AKINYEMI
At-Large

VINCENT S. LONG
County Administrator

HERBERT W.A. THIELE
County Attorney

October 7, 2011

RE: Bid Title: Leon County Sustainable Demonstration Center - Electrical; Bid
No: BC-10-11-11-08
Opening Date: Tuesday, October 11, 2011 at 4:00 PM

ADDENDUM #2

Dear Vendor:

This letter serves as Addendum #2 for the above referenced project.

Please see the attached Addendums 2 (2 pages each) for both the Electrical and the Photovoltaic Array from H2 Engineering, Inc.

Acknowledgment of this addendum is required as part of your bid submittal. Failure to acknowledge this addendum may result in rejection of your bid.

Should you have any questions, feel free to call me at (850) 606-1600.

Sincerely,

Keith M. Roberts
Purchasing Director



H2Engineering, Inc.
114 East Fifth Avenue
Tallahassee, FL 32303
Phone 850.224.7922
Fax 850.224.5876

ADDENDUM #2(BID PACKAGE # 3)

To: Jeff Williams	From: Peter Lindstrom
Co: Leon County	Date: October 06, 2011
Project: Leon County Sustainable Demonstration Center	Job #: 11-05

This Addendum forms a part of the Contract Documents and modifies the original Project Specifications, dated September 12, 2011, as noted below. This addendum consists of one (1) RFI response sheet.

PRE-BID RESPONSE:

Refer to attached sheet.

END OF DOCUMENT



RESPONSE TO PRE-BID RFI'S, BID PACKAGE # 3

To:	Jeff Williams	From:	Peter Lindstrom
Co:	Leon County Facilities Management	Date:	October 6, 2011
Project:	Leon County Sustainable Demonstration Center	Job #:	11-05


Pre-Bid Questions:

1. Will pad mounted inverters be allowed to be placed adjacent to the building in lieu of string inverters?
2. There are some trees on site creating shading problems to the proposed carport structure. Can they be removed/replaced or trimmed?
3. Can we propose our system to connect to the line side of the building's main electrical disconnect?
4. Will a Microinverter redesign be accepted?

The following responses are in reference to the Pre-Bid Questions as indicated above

1. No.
2. The trees will be trimmed by Leon County Facilities as needed.
3. Yes, following code and presenting a neat and professional installation.
4. Yes.

END OF DOCUMENT



RESPONSE TO PRE-BID RFI'S, BID PACKAGE # 4

To:	Jeff Williams	From:	Peter Lindstrom
Co:	Leon County Facilities Management	Date:	October 6, 2011
Project:	Leon County Sustainable Demonstration Center	Job #:	11-05

Pre-Bid Question:

1. Page 263100-2 Part 2-Products, 2.1 Manufacturer Units: Can Florida based PV manufacturer "Advanced Solar Photonics" photovoltaic modules be added to the product list?

The following response is in reference to the Pre-Bid Question as indicated above:

1. Yes. Refer to Addendum # 2.

END OF DOCUMENT