



# Leon County

## Board of County Commissioners

301 South Monroe Street, Tallahassee, Florida 32301  
(850) 606-5302 www.leoncountyfl.gov

Purchasing Division  
1800-3 Blair Stone Road  
Tallahassee, Florida 32308  
(850) 606-1600

Commissioners

BILL PROCTOR  
District 1

JANE G. SAULS  
District 2

JOHN DAILEY  
District 3

BRYAN DESLOGE  
District 4

BOB RACKLEFF  
District 5

CLIFF THAELL  
At-Large

AKIN AKINYEMI  
At-Large

PARWEZ ALAM  
County Administrator

HERBERT W.A. THIELE  
County Attorney

October 8, 2010

RE: ITN Title: Design and Installation of Electrical Power Production at the Leon County Solid Waste Management Facility (SWMF)  
ITN No: BC-10-20-10-49  
Opening Date: Wednesday, October 20, 2010

### ADDENDUM # 2

Dear Vendor:

This letter serves as Addendum #2 for the above referenced project.

The information below is provided in response to vendor inquiries.

1. What is the total volume (tons per year) of municipal solid waste delivered per annum at this landfill, then if possible, the total volume (tons per year) of organic waste.

**There are approximately 27,000 tons of yard debris annually. There are no other types of organic materials accepted at the Apalachee facility.**

2. Would it be possible to obtain copies of the electrical bills for 2009, or at least a seasonal representation of a couple months so that we can get a thorough understanding of the load requirements?

**There are multiple meters at the SWMF, about 13 all together. The total load average for January 2009 and July 2009 was 20,611 kwh.**

**January 2009 - 27,360 kwh  
July 2009 - 13,762 kwh**

3. How many acres does the current LFG collection system cover?

**Approximately 53 acres.**

4. What is the currently permitted landfill footprint?

**53 acres, Class I. A permit mod to add an additional 30 feet has been approved.**

5. What is the maximum height of waste at the landfill?

**40 ft. above grade. Grade is at 100 ft.**

6. Has a siloxane analysis of the LFG been performed?

**No.**

Acknowledgment of this addendum is required as part of your bid submittal. Failure to acknowledge this addendum may result in rejection of your bid.

Should you have any questions, feel free to call me at (850) 606-1600.

Sincerely,

A handwritten signature in cursive script that reads "Wendi Sellers".

Wendi Sellers  
Contract Manager