



Leon County

Board of County Commissioners

301 South Monroe Street, Tallahassee, Florida 32301
(850) 606-5302 www.leoncountyfl.gov

Purchasing Division
2284 Miccosukee Road
Tallahassee, Florida 32308
(850) 606-1600

Commissioners

BILL PROCTOR
District 1

JANE G. SAULS
District 2

JOHN DAILEY
District 3

BRYAN DESLOGE
District 4

BOB RACKLEFF
District 5

CLIFF THAELL
At-Large

AKIN AKINYEMI
At-Large

PARWEZ ALAM
County Administrator

HERBERT W.A. THIELE
County Attorney

August 2, 2010

RE: Bid Title: Hawkbill Court Drainage Improvements
Bid No: BC-08-05-10-46
Opening Date: August 5, 2010 at 2:00 PM

ADDENDUM # 3

Dear Vendor:

This letter serves as Addendum #3 for the above referenced project.

The following shall be added to the bid specifications.

Question: Bid Sheet list Item 524-1-2, Concrete Ditch Pavement, as **NON REINFORCED.**

However, plan sheet 5 has a detail for Main Drainage Ditch Pavement and Note 2 states that the concrete ditch pavement shall be constructed of Class I Concrete (FIBER REINFORCED) with a minimum of 28 day compressive strength of 3000 psi.

Answer: The plans sheet is correct.

Acknowledgment of this addendum is required as part of your bid submittal. Failure to acknowledge this addendum may result in rejection of your bid.

Should you have any questions, feel free to call me at (850) 606-1600.

Sincerely,

Don Tobin, CPPB
Purchasing Agent

DT