


REPORT OF TESTS

ORGANIC CONTENT				SIEVE ANALYSIS RESULTS % PASSING							PLASTICITY			CLASSIFICATION		DESCRIPTION	
STRATUM NO.	NO. OF TESTS	% ORGANIC	MOISTURE CONTENT (%)	NO. OF TESTS	4 MESH	10 MESH	20 MESH	40 MESH	100 MESH	200 MESH	NO. OF TESTS	LIQUID LIMIT	PLASTICITY INDEX	UNIFIED GROUP	AASHTO GROUP	COLOR	MATERIAL
1	--	--	--	1	100	100	99	86	27	16	--	--	--	SM	A-2-4	BROWN	SILTY FINE SAND
2	--	--	--	3	100	100	88-99	55-91	25-31	23-28	1	39	18	SC	A-2-6	BROWN	CLAYEY FINE SAND
3	--	--	-	13	100	100	99-100	81-99	38-81	36-49	9	32-39	14-26	SC	A-6	BROWN GRAY	CLAYEY SAND
4	--	--	--	7	100	100	100	82-100	50-97	51-94	6	51-117	24-87	CH	A-7-6	BROWN GRAY	HIGHLY PLASTIC CLAY



REVISIONS		
DATE	REV.	REVISION
8-16-13	1	CORRECTED WATER LEVELS

Environmental & Geotechnical Specialists, Inc.
EGS
 3154 ELIZA ROAD
 TALLAHASSEE, FLORIDA 32308
 OFFICE: (850) 386-1253
 FAX: (850) 385-8050
 Cert. of Auth.: 6222

LEON COUNTY
PROJECT TITLE
LAUDER POND EMBANKMENT SEEPAGE

REPORT OF CORE BORINGS
 SHEET 2 OF 2

SHEET NO.
 22